

DECLARATION OF PERFORMANCE (DoP)

Date of issue: 27.10.2017

Replaces: No. 1121-CPR-15/0569-2015/9 of 15/09/2015

No. 1121-CPR-15/0569-2017/10

1	Unique identification of the product-type: PROMASEAL[®] Fire Compound		
2	Type and batch numbers: as given on the packaging of the product		
3	Intended uses as given in the ETA-15/0569: 3.1 - PROMASEAL [®] Fire Compound is a gypsum based mortar material used to reinstate the fire resistance performance of floor constructions where they have been provided with apertures for the penetration of multiple services Cable penetrations – Insulated & non-insulated, cables, cable trays and cable ladders 3.2 - The product is intended for: - use in internal conditions with humidity \geq 85%, excluding temperatures below 0°C, without exposure to rain and UV (TR 024:2009, type Z ₁)		
4	Name and contact address of the manufacturer: Etex Building Performance Limited Gordano House, Marsh Lane Easton-in-Gordano, Bristol, BS20 0NE www.promat.co.uk Manufacturing Plant: E105		
5	Authorised representative: not applicable.		
6	System or systems of Assessment and Verification of Constancy of Performance (AVCP): AVCP – System 1		
7	The construction product is not covered by a harmonised standard (hEN).		
8	The declaration of performance concerns a construction product for which a European Technical Assessment has been issued. Warrington Certification Limited (WCL) has issued an ETA for this product with no. ETA-15/0569 based on ETAG 026-2 (used as EAD)		
	Notified product certification body: No. 1121 (Warrington Certification Limited) - Certificate of Constancy of Performance No. 1121- CPR-JA5079		
	Essential characteristics	AVCP systems	Performance
			Harmonised technical specification
	BR1: Mechanical resistance and stability.		
	BR2: Safety in the case of fire:		
	Reaction to fire:	1	Class F according to EN13501-1
	Resistance to fire:	1	ETA 15/0569 Clauses 3.1
			ETA 15/0569 Clauses 3.2 & Annex C
			This characteristic depends on the tested assembly. Fire resistant constructions have been tested and the performance class has been established in a classification document in accordance with EN13501-2
	BR3: Hygiene, Health and the Environment:		
	Air permeability:	-	Tested in accordance with EN1314-1
	Water impermeability:	-	NPD (No Performance Declared)
	Release of dangerous substances:	-	Declaration (filed with the Technical Approval Body)
			ETA 15/0569 Clause 3.3
			ETA 15/0569 Clause 3.4
			ETA 15/0569 Clause 3.5

BR4: Safety and accessibility in use:			
Mechanical resistance and stability:	-	NPD (No Performance Declared)	ETA 15/0569 Clause 3.6
Resistance to impact and movement:	-	NPD (No Performance Declared)	ETA 15/0569 Clause 3.7
Adhesion:	-	NPD (No Performance Declared)	ETA 15/0569 Clause 3.8
BR5: Protection against noise:			
Airborne sound insulation:	-	NPD (No Performance Declared)	ETA 15/0569 Clause 3.9
BR6: Energy Economy and Heat Retention:			
Thermal conductivity:	-	NPD (No Performance Declared)	ETA 15/0569 Clause 3.10
Water vapour permeability (transmission coefficient):	-	NPD (No Performance Declared)	ETA 15/0569 Clause 3.11
Durability:			
Basic durability assessment:	-	In accordance with the declared use, class Z ₁ according EOTA TR024 and in conformity with ETAG 026-2	ETA 15/0569 Clause 3.12

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

A Safety Data Sheet (SDS) is available upon request.

Signed for and on behalf of the manufacturer by:

Name: Nigel Morrey
Function: Technical Director



Signature:

Easton-in-Gordano, Bristol, 27th October 2017